

## City of Granbury Fire Lane Standards

### Fire Lane Markings

Fire Lanes shall be marked on the curb face when at all possible and transition to the flat part when broken. The marking shall consist of a six (6) inch red stripe with the words FIRE LANE NO PARKING TOW-AWAY-ZONE in white four (4) inch letters. The labels shall be placed every twenty-five (25) feet. THERE SHALL BE APPROXAMETLY TWO (2) INCHES BETWEEN FIRE LANE AND NO PARKING AND TOW-AWAY-ZONE. The curb shall be painted when applicable. All markings shall be approved by the City of Granbury Fire Marshal.

**FIRE LANE NO PARKING TOW-AWAY-ZONE**

Fire lanes shall be Engineered to withstand load of 80,000 lbs. (IFC Section 503.2.3 with COG Amendments)

Fire Lane Radius to be 28" Typical, minimum Fire Lane width is 24 feet. (503.2.1 with COG Amendments)